

NOTES:

1. TAP ON THE MAIN SHALL BE MADE IN THE POSITION SHOWN.
2. LOCATE MANHOLE AS SHOWN ON THE PLAN OR AS DIRECTED BY THE ENGINEER.
3. MANHOLE COVER SHALL BE FLUSH WITH FINAL GRADE

12" DRAIN HOLE FILLED W/ STONE

MANHOLE STEPS

12" SQUARE

FORCE MAIN

TRAFFIC RATED MANHOLE FLAT-TOP

24" MH FRAME AND COVER

SHORT BODY COMBINATION AIR VALVE

4' DIA. PRECAST MANHOLE

GROUT OPENING BETWEEN PIPE AND MANHOLE

2" GATE VALVE

2" 90°

2" 90°

2" THREADED BRASS PIPE

CONCRETE PAD

2" CORP. STOP

DEPTH AS REQUIRED

12"

ABC STONE BASE

2" TAPPING SADDLE

## **AUTOMATIC AIR RELEASE VALVE**

**NOT TO SCALE**



## City of New Bern

ENGINEERING DEPARTMENT, PO Box 1129  
NEW BERN NC 25263-1129  
252.639.7526 (FAX) 252.672.5152  
[www.newbern-nc.org](http://www.newbern-nc.org)